

Town of Warrenton Sewer Collection System

Performance Annual Report
July 1, 2012 – June 30, 2013

I. General Information

Facility Name: Town of Warrenton Sewer Collection System

Responsible Entity: Town of Warrenton

Person in Charge/Contact: Bill Perkinson, Public Works Director 252-257-1776

Applicable Permits: WQCS00092

System Description

The Town of Warrenton operates and maintains a wastewater collection system consisting of approximately 21 miles of gravity sewer, approximately 8 miles of force sewer main, 4 duplex sewer pump stations, and all associated piping, valves, and accessories required to make a complete and functional wastewater collection system that serves the Town of Warrenton.

II. Performance

The Town of Warrenton Collection System was compliant with all guidelines of its Operating Permit issued by the State of North Carolina and had no operating violations throughout the entire twelve month period.

The system experienced one sanitary sewer overflow on June 7, 2013 due to a severe natural condition. The condition involved heavy rain as a result of tropical storm Andrea. Just prior to the sanitary sewer overflow rain fell at a rate of 2.0 inches per hour. A total of 5.8 inches of rain fell over an 18 hour period. 900 gallons of raw sewer spilled into Horse Branch (manholes no. 13 and 14) near the intersection of Franklin Street and Earlene Lane. The overflow area was cleaned, raked, and treated with lime.

III. Notification

This report has been made available to the residents of the Town of Warrenton and will be published in the Warren Record Newspaper.

IV. Certification

I certify under penalty of law that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system and that those users have been notified of its availability.

Bill Perkinson
Public Works Director
Town of Warrenton